



Certificate of Compliance

This certificate is issued for the following:

Polyethylene Pipe for Underground Fire Protection Service

<i>Product Designation</i>	<i>O.D., Pipe Size, in.</i>	<i>Pressure Rating, psi (kPa)</i>	<i>Remarks</i>
PC160, SDR11 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 24	160 (1105)	a, b
PC200, SDR9 Pipe	4, 6, 8, 10, 12, 14, 16, 18	200 (1380)	a, b
PC250, SDR7.3 Pipe	8	250 (1725)	a, b

Remarks:

- a. Pipe and fittings may be directly connected together by the butt fusion process. Manufacturer's fusion instructions must be strictly followed for a proper fusion joint.*
- b. FM Approved in iron pipe sized diameter basis.*

Prepared for:

Plastics Technology de Mexico S. de R.L. de C.V.
Ave Montes Urales 8, Parque Opcion Los Nogales
San Jose Iturbide, Guanajuato 37980
Mexico

Manufactured at:

Plastics Technology de Mexico S. de R.L. de C.V.
Ave Montes Urales 8, Parque Opcion Los Nogales
San Jose Iturbide, Guanajuato 37980
Mexico

FM Approval Standard Class 1613 (February 2017)

Approval Identification: PR454617

Approval Granted: July 6, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group